



Jim Doyle, Governor
Mary P. Burke, Secretary

January 20, 2005

MULTI-FLO OF WISCONSIN
JAMES R. BAKER
7330 U.S. HWY 14 W, PO BOX 714
JANESVILLE WI 53547-0714

CONSOLIDATED TREATMENT SYSTEMS
BENNETTE D. BURKS
1501 COMMERCE CENTER DR
FRANKLIN OH 45005

Re: Description: SEWAGE TREATMENT SYSTEMS, AERATED
Manufacturer: CONSOLIDATED TREATMENT SYSTEMS
Product Name: MULTI-FLO WASTEWATER TREATMENT PLANT
Model Number(s): FTB 1.0 (1000 GPD)
Product File No: 20040649

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of January 2010.

This approval is contingent upon compliance with the following stipulation(s):

- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- The maximum daily wastewater flow which may discharge through this product is 1000 gallons per day.
- When this product receives wastewater from dwellings, it will produce an effluent quality with a maximum monthly average value for BOD5 of less than or equal to 30 mg/L, TSS of less than or equal to 30 mg/L TSS and F.O.G. of less than 30 mg/L and fecal coliform of less than or equal to 10,000 cfu/100ml.

This approval supersedes the approval issued on July 5, 2000, under product file number 20000967.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20000967.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Michael J. Beckwith, CIPE
Plumbing Product Reviewer
phone: 608-266-6742
fax: 608-267-9566
e-mail: mike.beckwith@wisconsin.gov